



Ministry of Environment
112-Research Drive
Saskatoon, SK. SN 3R3
Ph (306-933-8367)
Fax (306-933-8442)

August 11, 2011

Town of Dalmeny
P.O. Box 400
DALMENY, SK S0K 1E0

Dear Waterworks Owner/Operator:

RE: Precautionary Drinking Water Advisory

Please be advised that the Ministry of Environment is rescinding the Precautionary Drinking Water Advisory for the Town of Dalmeny's distribution system, which was issued on August 8, 2011 at 11:15 am, effective immediately.

All repair work to the water main, has been completed and the proper measures have been taken to put the Dalmeny distribution system back into service. All necessary bacteriological samples have been taken, and have come back with good results. No positive bacteria were found in the two sets of samples.

In consultation with the Saskatoon Health Region, we agree no potential health risk currently exists for the Town of Dalmeny distribution system, and the advisory previously issued is hereby removed.

If you have any further questions or concerns please do not hesitate to contact me at (306-933-8367).

Sincerely,

Lee Reinhart
Environmental Project Officer
Ministry of Environment
Saskatoon, SK.

cc. Bill Miller, Manager, Environmental Services Section North, MOE
Saskatoon Health Region
Municipal Branch, Regina
Barbara Barootes, Communications Consultant, Communications Branch, Regina
Roger Miller, Environmental Project Officer, Municipal Branch, Moose Jaw